



Municipality of Anchorage



Policy P.01

Single-Wall Heat Exchanger

Based upon the State of Alaska amendments, we will follow their requirements, as outlined below. This policy modifies Local Amendment 23.25. Appendix L to the Uniform Plumbing Code.

A single-wall heat exchanger may be used if:

1. The heat transfer medium is water or propylene glycol without toxic additives;
2. The pressure of the heat transfer medium is limited to a maximum of 30 pounds per square inch by an approved safety relief valve; and
3. The heat exchanger is prominently and permanently labeled with instructions concerning (1) and (2) of this policy.

Ron Thompson, Building Official

DATE: April 17, 2006

(Ref: 03-05)