



**ANCHORAGE FIRE DEPARTMENT
FIRE PREVENTION
4700 Elmore Anchorage, Alaska 99507
(907) 267-4900**

**Policy # 08-005 LOCKING KNOX CAPS ON FIRE DEPARTMENT CONNECTIONS (FDC'S)
AND STANDPIPES**

References: IFC 912.3.1

Locking Knox caps may be required on FDC's and dry standpipe connections when a history of vandalism or other public damage has occurred which threatens to compromise the operation of the fire suppression systems in the building.

Buildings in areas that are subject to high public use and/or visibility may require locking caps or other protections. The Fire Inspector or other responsibility party shall bring the specific building condition to the attention of the Fire Marshal for a determination before making the requirement mandatory.