



ANCHORAGE FIRE DEPARTMENT
FIRE PREVENTION
4700 Elmore Anchorage, Alaska 99507
(907) 267-4900

Policy # 08-009 Fire Department Connections Building Sign Posting Policy

References: IFC 912.2

Where not clearly visible from the front main entrance to the building, Fire Department Connection signage is required at exterior FDC's.

If the FDC is visible to approaching fire apparatus, then no signage will be required.