




Municipality of Anchorage




Handout F.02


Recommended Dead-End Fire Lane Turnarounds




96' DIAMETER
CUL-DE-SAC




60' "Y"



MINIMUM CLEARANCE
AROUND A FIRE
HYDRANT



120' HAMMERHEAD



ACCEPTABLE ALTERNATIVE
TO 120' HAMMERHEAD

Mark Hall, Fire Chief
DATE: September 27, 2010
(Ref. 96-01, 00-03, 06-02)