

Application for Fill/Grading Permit: Handout No. 46
Revised 4-20-01



Del Isabelle
P. O. Box 220021
Anchorage, AK 99522-0021
(907) 243-5845 / fax (907) 248-0004

SUBMITTAL

APR 23 2001
00-6083
GRETCHEN STULLER
April 20, 2001

As per item numbers:

1. Legal Description: Seaview Heights, Blk 2, Lot 7B
2. Amount of materials to be excavated/filled: less than 50,000 cu. Yd.
3. Type of material: Silt & organic fill, type pending.
4. Source of material: Any available, pending
5. Two site plans to scale showing limits: See attached with revisions
6. Cross sections to scale showing existing & final grades: See attached with revisions
7. Statement of intended purpose of fill: This property currently has an existing grade drop at the front of the lot that is approximately 15' below the roadway elevation. I will be clearing and grubbing existing organic in the proposed driveway and low lying ground to place fills as necessary to obtain road access to the main portion of the site. I intend to build my home on the property in the near future.
8. Wetland permit: Not a wet site or any current drainage courses or problems.
9. Flood Hazard permit: N/A



EASEMENTS OF RECORD, OTHER THAN
THOSE SHOWN ON THE RECORDED
PLAT ARE NOT SHOWN HEREON.

Proposed Topo A-11-01
PROPOSED CONSTRUCTION PLAN

I hereby certify that I have surveyed the following described
property:
LOT 78, BLOCK 2,

SEAVIEW HEIGHTS SUBDIVISION

Anchorage Recording Precinct, Alaska, and that the improve-
ments situated thereon are within the property lines and do not
overlap or encroach on the property lying adjacent thereto, that
no improvements on property lying adjacent thereto encroach
on the premises in question and that there are no roadways,
transmission lines or other visible easements on said property
except as indicated hereon:

Dated at Anchorage, Alaska

This 30th day of JANUARY, 2001

BE (907) 248-1668

FRED WALATKA & ASSOCIATES
Engineers and Surveyors

FILL & GRADING
 CO-6093 C.O. #1
 SEE REVERSE

APPROVED

Cynthia Kurlin

BY _____
 DATE 5/11/01


APPROVED PLANS AND SPECIFICATIONS SHALL NOT BE
 CHANGED, MODIFIED, OR ALTERED WITHOUT AUTHORIZATION
 FROM THE ADMINISTRATIVE AUTHORITY AND ALL WORK SHALL
 BE DONE IN ACCORDANCE WITH APPROVED PLANS.

THIS SET OF PLANS SHALL BE KEPT ON SUCH BUILDING OR
 WORK AT ALL TIMES DURING WHICH THE WORK AUTHORIZED
 THEREBY IS IN PROGRESS.

MUNICIPAL BUILDING CODE


Validity. "The issuance or granting of a permit or approval of plans and specifications shall not be construed to be a permit for, or an approval of, any violation of any of the provisions of this Code. No permit presuming to give authority to violate or cancel the provisions of this Code shall be valid, except insofar as the work or use which it authorizes is lawful."

"The issuance of a permit based upon plans and specifications shall not prevent the Building Official from thereafter requiring the correction of errors in said plans and specifications or from preventing building operations being carried on thereunder when in violation of this Code or of any other ordinance of the municipality."



APPROVED
79
MAY 08 2001

CYNTHIA KUSTIN



APPROVED


MAY 08 2001

CYNTHIA KUSTIN

Supply &
Install

16" culvert

match ditch
line West invert
0% slope



CROSS SECTION

LORI DR. (Center Line) **APPROVED**

MAY 08 2001

and driveway

Notes: 1. Compact Fill to 90% max. density

2 - Slopes shall not exceed 2 H : 1 L.

3 - Set backs from property lines shall be maintained.
Top of fill slopes shall not be nearer than
one half the height of fill but need not exceed
20 ft. The minimum distance = 2'

CYNTHIA KUSTIN